



**SECTION BB**

TYPE OF DRIVEWAY	SURFACING REQUIREMENTS	BASE ROCK REQUIREMENTS
CONCRETE	6" OF 3000 PSI PORTLAND CEMENT CONCRETE	2' OF SAND OR 2' OF 3/4"-0 CRUSHED ROCK
ASPHALT	3" OF ASPHALTIC CONCRETE PAVEMENT	6' OF 1'-0 CRUSHED AGG BASE ROCK
GRAVEL (LESS THAN 300 TRIPS/YR)	2" OF 3/4"-0 CRUSHED ROCK	6' OF 1'-0 CRUSHED AGG BASE ROCK

**NOTES:**

- IF THE CULVERT IS LARGER THAN 15" IN DIAMETER THE ENDS SHALL BE MITERED 2:1.
- ALL SURFACES AND BASE ROCK SHALL BE COMPACTED.
- LOW USE AGRICULTURAL LAND AND LOGGING ACCESS MAY BE SURFACED WITH GRAVEL OUTSIDE OF UGB'S.
- DRIVEWAYS THAT CANNOT CONFORM TO SECTION BB ABOVE, SHALL BE CONSTRUCTED WITH A 3% CROWN TO PREVENT WATER FROM RUNNING ONTO THE MAIN ROADWAY. THIS MUST BE APPROVED BY BENTON COUNTY.
- LAY GROOVE END OF PIPE UPSTREAM.

BENTON COUNTY PUBLIC WORKS	
STANDARD DRIVEWAY	
COUNTY	
APPROVED BY JAMES E. BLAIR, ENGINEER	
DRAWN BY :	TANYA K.
PLOT DATE :	06-29-98
filename:	F:\COMMON\ENG_SUR\DRIVE_3.dwg
location:	F:\COMMON\ENG_SUR\