



28972 Coffin Butte Rd Corvallis, OR 97330  
o 541.745.5792 f 541.230.5534 republicservices.com

February 17, 2022

Corvallis Public Works Department  
Attention: Shane Sinclair  
1245 NE 3<sup>rd</sup> Street  
P.O. Box 1083  
Corvallis, OR 97339-1083

**RE: Wastewater Discharge Report for January 2022**

Dear Mr. Sinclair,

Enclosed is our submittal of the Valley Landfills, Inc. Wastewater Discharge Report for January 2022, as required by the City of Corvallis Industrial Wastewater Discharge Permit No. 5 effective June 1, 2018.

I make the following certifications:

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I certify under penalty of law, that to the best of my knowledge and belief, the sampling and analysis were performed in accordance with 40 CFR Part 136.

Please contact Ian Macnab or Broc Kienholz at (541) 745-5792 if you have any questions or require additional information.

Sincerely,

A handwritten signature in black ink, appearing to read "Broc Kienholz", written over a horizontal line.

Broc Kienholz  
Operations Manager

Enclosure: Wastewater Discharge Report for January 2022

Day	Hg (Total) (mg/L) (lb/Day)	Mo (Total) (mg/L) (lb/Day)	Ni (Total) (mg/L) (lb/Day)	Se (Total) (mg/L) (lb/Day)	Ag (Total) (mg/L) (lb/Day)	Zn (Total) (mg/L) (lb/Day)	Cyanide (Total) (mg/L) (lb/Day)	Ammonia-N (mg/L)	TDS (mg/L)
1									
2									
3									
4									
5			0.104			<0.005		739.2	
6									
7									
8									
9									
10									
11									
12	<0.001	<0.0006	0.1358	<0.005	<0.01	0.057	0.00930	700	6492
13									
14									
15									
16									
17									
18									
19			0.1215			0.0622	0.00563	733.6	
20									
21									
22									
23									
24									
25									
26			0.0640			0.0160	0.00563	761.6	
27									
28									
29									
30									
31									
<b>TOTAL</b>									
<b>MAXIMUM</b>	<0.0006	<0.0006	0.108	<0.003	<0.006	0.035	0.00563		
<b>MINIMUM</b>									
<b>DAILY MAXIMUM</b> (lb/Day)			0.36			0.91			

Signed By:



Broc Kienholz  
Operations Manager  
Page 2 of 2

Day	Flow (gpd)	% Leachate in WWRP Flow	pH (Std. Units)	As (Total) (mg/L) (lb/Day)	Cd (Total) (mg/L) (lb/Day)	Cr (Total) (mg/L) (lb/Day)	Cu (Total) (mg/L) (lb/Day)	Pb (Total) (mg/L) (lb/Day)
1	37,196	0.22						
2	38,435	0.21						
3	126,300	0.47						
4	126,280	0.52						
5	124,724	0.52	7.5	0.0708		0.105	0.109	
6	124,036	0.52						
7	70,038	0.31						
8	36,676	0.19						
9	19,088	0.10						
10	64,402	0.40						
11	76,246	0.60						
12	72,630	0.60	7.7	0.0633	<0.001	0.1248	0.07560	0.0050
13	73,124	0.6			<0.0006			0.0030
14	56,153	0.50						
15	37,017	0.36						
16	20,523	0.20						
17	59,450	0.60						
18	49,303	0.52						
19	55,971	0.58	7.6	0.073		0.166	0.0775	
20	57,115	0.60						
21	46,579	0.53						
22	37,400	0.44						
23	23,631	0.27						
24	51,586	0.60						
25	50,364	0.60						
26	48,897	0.60	7.6	0.0785		0.117	0.0477	
27	48,696	0.60						
28	40,452	0.52						
29	33,861	0.45						
30	17,726	0.18						
31	52,745	0.60						
<b>TOTAL</b>	<b>1,776,644</b>							
<b>MAXIMUM</b>	<b>126,300</b>	<b>0.60</b>	<b>7.7</b>	<b>0.0736</b>	<b>&lt;0.0006</b>	<b>0.109</b>	<b>0.0030</b>	<b>&lt;0.0006</b>
<b>MINIMUM</b>	<b>17,726</b>		<b>7.5</b>					
<b>DAILY MAXIMUM (lb/Day)</b>			<b>6.0 - 9.5</b>	<b>0.42</b>		<b>0.60</b>		

Notes:  
 Day = 8:00 AM to 8:00 AM  
 < = Less than