



28972 Coffin Butte Rd Corvallis, OR 97330
o 541.745.5792 f 541.230.5534 republicservices.com

December 17, 2021

Corvallis Public Works Department
Attention: Shane Sinclair
1245 NE 3rd Street
P.O. Box 1083
Corvallis, OR 97339-1083

RE: Wastewater Discharge Report for November 2021

Dear Mr. Sinclair,

Enclosed is our submittal of the Valley Landfills, Inc. Wastewater Discharge Report for November 2021, as required by the City of Corvallis Industrial Wastewater Discharge Permit No. 5 effective June 1, 2018.

I make the following certifications:

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

I certify under penalty of law, that to the best of my knowledge and belief, the sampling and analysis were performed in accordance with 40 CFR Part 136.

Please contact Ian Macnab or Broc Kienholz at (541) 745-5792 if you have any questions or require additional information.

Sincerely,


Broc Kienholz
Operations Manager

Enclosure: Wastewater Discharge Report for November 2021

Day	Flow (gpd)	% Leachate in WWRP Flow	pH (Std. Units)	As (Total) (mg/L) (lb/Day)	Cd (Total) (mg/L) (lb/Day)	Cr (Total) (mg/L) (lb/Day)	Cu (Total) (mg/L) (lb/Day)	Pb (Total) (mg/L) (lb/Day)					
1	53,662	0.60											
2	43,840	0.60											
3	75,674	0.58	7.7	0.0762	0.0481	<0.001	<0.0003	0.160	0.101	0.0080	0.0050	<0.001	<0.0003
4	89,330	0.56											
5	87,606	0.58											
6	93,470	0.57											
7	58,737	0.43											
8	78,318	0.58											
9	70,342	0.60											
10	92,938	0.50	7.8	0.076	0.059								
11	99,900	0.54							0.175	0.136			
12	96,386	0.59											
13	54,002	0.49											
14	27,450	0.29											
15	40,427	0.33											
16	55,183	0.60											
17	50,380	0.60	7.9	0.078	0.033				0.1615	0.06786			
18	58,022	0.60											
19	50,831	0.60											
20	46,640	0.59											
21	46,294	0.60											
22	53,127	0.60											
23	54,957	0.60	7.8	0.0628	0.0288				0.171	0.0784			
24	45,891	0.60											
25	51,661	0.60											
26	49,847	0.60											
27	53,472	0.60											
28	48,434	0.60											
29	47,098	0.60											
30	44,828	0.60											
TOTAL	1,818,747												
MAXIMUM	99,900	0.60	7.9										
MINIMUM	27,450		7.7										
DAILY MAXIMUM (lb/Day)													

Notes:
 Day = 8:00 AM to 8:00 AM
 < = Less than

Day	Hg (Total) (mg/L)	(lb/Day)	Mo (Total) (mg/L)	(lb/Day)	Ni (Total) (mg/L)	(lb/Day)	Se (Total) (mg/L)	(lb/Day)	Ag (Total) (mg/L)	(lb/Day)	Zn (Total) (mg/L)	(lb/Day)	Cyanide (Total) (mg/L)	(lb/Day)	Ammonia-N (mg/L)	TDS (mg/L)
1																
2																
3	<0.001	<0.0003	<0.017	<0.0048	0.141	0.0890	<0.005	<0.001	<0.01	<0.003	0.0299	0.0189	0.01300	0.00820	1080.8	9358
4																
5																
6																
7																
8																
9																
10					0.125	0.0969					0.0480	0.0372			980	
11																
12																
13																
14																
15																
16																
17					0.118	0.0494					0.024	0.010			952	
18																
19																
20																
21																
22																
23					0.1125	0.05156					0.021	0.010			912.8	
24																
25																
26																
27																
28																
29																
30																
TOTAL																
MAXIMUM		<0.0003		<0.0048		0.097		<0.001		<0.003		0.0372		0.00820		
MINIMUM																
DAILY MAXIMUM (lb/Day)					0.36						0.91					

Signed By: 
 Broc Kienholz
 Operations Manager
 Page 2 of 2