

## Recovery Worksheet

Ending Water Level (at completion of 4  
or 12 hours of sustained yield pumping

*minus*

Pre-pumping static water level

*equals*

Drawdown

X 0.9

90% of Drawdown

Ending Water Level (at completion of 4  
or 12 hours of sustained yield pumping

*minus*

90% of Drawdown

*equals*

Recovery Target Level

**Record water level for 4 hours**

**or**

**until water level returns to**

Revised 4/20/09

## Recovery Worksheet – EXAMPLE

Ending Water Level (at completion of 4  
or 12 hours of sustained yield pumping)

100'

*minus*

Pre-pumping static water level

20'

*equals*

Drawdown

80'

X 0.9

90% of Drawdown

72'

Ending Water Level (at completion of 4  
or 12 hours of sustained yield pumping)

100'

*minus*

90% of Drawdown

72'

*equals*

Recovery Target Level

28'

Record water level for 4 hours  
or  
until water level returns to

28'

Revised 4/20/09